



DELHI AVIATION FUEL FACILITY PRIVATE LIMITED

(Joint Venture of IOCL, BPCL & DIAL)

Regd. Office: Aviation Fuelling Station, Shahbad Mohammad Pur, IGI Airport, New Delhi - 110 061, INDIA

26/05/2020

Corrigendum I - Tender No: DAFFPL/MOD/FF/2019-20/15

SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF AUTOMATIC NOVEC 1230 GAS BASED FIRE SUPPRESSION SYSTEM FOR CONTROL ROOM

Dear Sir,

All prospective Bidders may please note that because of the issues/queries raised as Pre-Bid queries which have been reviewed and deliberated upon by DAFFPL, corrigendum is being hereby issued to address the queries.

- **System Bar Rating:** Design requirements are mentioned in Clause 6 of specifications of CAFES. Bidder must specify the system rating based on the calculations.
- **Approved Makes:**

S No	Details of Materials / Equipment	Manufacturers Name
1	NOVEC 1230 Gas	3M, USA
2	Seamless cylinder	Worthington / Rama / EKC
3	Seamless pipe	Maharashtra / BHEL / Jindal
4	Electric actuator	UTC / SERVO / VIKING / Ceasefire
5	Pressure actuator	UTC / SERVO / VIKING / Ceasefire
6	Manual actuator	UTC / SERVO / VIKING / Ceasefire
7	Discharge nozzle	UTC / SERVO / VIKING / Ceasefire
8	Discharge Pressure switch	UTC / SERVO / VIKING / Ceasefire
9	Flexible Discharge Hose	UTC / SERVO / VIKING / Ceasefire
10	Manifold Check Valve	UTC / SERVO / VIKING / Ceasefire
11	Actuator hose	UTC / SERVO / VIKING / Ceasefire
12	Armoured cable	Polycab / Finolex / Havells
13	Fire alarm and detection system	Notifier / System Sensor / GE

Further, for ensuring competitive tendering process DAFFPL has decided to extend the last date for submission of tender. The final date of submission of tender will now be **10th June 2020 till 1500 Hrs** and Opening of Technical Bids will be on **11th June 2020 @ 1100 Hrs**. All other conditions in the tender will remain unchanged.

Please submit your bid in line with the revised specifications.

Rakesh Arora
Chief Executive Officer
DAFFPL