

CONSOLIDATE PREBID QUERIES REPLY-MOV & HOV (DAFFPL/FF/2021-22/05)

Sr. No.	Document No. DAFFPL/FF/2021-22/05	Clause	Description / Requirements	Bidders/Vendors Queries	SAGA/DAFFPL Response
1	Page 7	15. EMD	Earnest Money Deposit	Not applicable , GOI has waived off the requirement of same. Udhyam Certificate attached in mail	Firms which are registered under MSME / NSIC are exempted from EMD. Valid certificate to be uploaded along with bid documents as mentioned in tender document.
2	Page 8	16. Delviery Period	Time frame for all items	30 weeks from GAD approval, manufacturing clearance and advance receipt	It shall be as per tender document
3	Page 10	27. CPBG	CONTRACT PERFORMANCE BANK GUARANTEE [CPBG]	Not Considered, as GOI has waived off the requirement of same.	It shall be as per tender document
4	Page 28	11. PRICE REDUCTION FOR DELAY IN DELIVERY	Delayed Delivery	LD : 0.5% per week to maximum of 5% of undelivered basic portion	It shall be as per tender document
5	Page 30	15. GUARANTEE/WARRANTY		12 months from date of invoice or 18 months from date of commissioning whichever is earlier against poor workmanship.	It shall be as per tender document
6	Page 31	18. Payment Terms		Payment terms : 10% advance along with PO, 20% within 15 days of submission of GADs, balance along with taxes against proforma invoice, payment shall be made in 5 working days of submission of proforma Invoice.	It shall be as per tender document
7	Page 31	18. Payment Terms	Performance Bank Gurantee	Not considered, L&T Valves shall provide warranty letter post supply of material.	It shall be as per tender document
8	Page 10 of 42	Pt number 4		we request you to advise if our (CAIR EUROMATIC AUTO.P.LTD.) valves along with Actuators are acceptable as single OEM	Acceptable but bidder shall fulfil all necessary terms and conditions of the tender documents along with Bid qualification criteria
9	Page no. 55 & 80 of 96	Clause no. 08 & note 02 of data sheet	It has been stated that valves shall be fire safe design.	Request for your clarification that It's relevant & applicable to actuators as electrical element & not applicable for valve as It's metal to metal seated valve	Electrical actuators shall be fire proof as per tender specifications whereas Valves shall be tested for fire as per API 6FA.