

**PREBID QUERIES REPLY - (TENDER NO - DAFFPL/FF/2022-23/12 )**

<b>Sr. No.</b>	<b>Bidders/Vendors Queries</b>	<b>DAFFPL Response</b>
1	Clause 2.1.1 of Technical specifications states that "The inlet and outlet of foam controller shall be provided with standard 63mm male and female couplings" This is required for JRCP whereas the tender mentions requirement of ILBP. Kindly confirm.	Only ILBP is required. Bidder to note that an provision to inject foam into the nozzle/monitor incase of ILBP malfunction through a hose pipe (hose pipe to be supplied along with remote operated monitor) is required.
2	Request you to kindly approve the following makes for Local Control Station: Sudheer Switch gear Pvt Ltd & Flameproof Equipment Pvt Ltd	Approved.